


Certificate of Conformity

Certificate Number: CN-PV-230559

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Elmark Industries SC 2 Dobrudzha blvd. , 9300, Dobrich, Bulgaria
Product:	Grid-connected PV inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	ELM3PON003K, ELM3PON004K, ELM3PON005K, ELM3PON006K, ELM3PON008K, ELM3PON010K, ELM3PON012K, ELM3PON013K, ELM3PON015K, ELM3PON017K, ELM3PON020K, ELM3PON025K
Brand Name<s>:	
Product Complies with:	EN 50549-1:2019 Requirements for the connection of generation equipment in parallel with public distribution networks.
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	2308A0284SHA-001

Additional information in Appendix.

Signature



Certification Manager: Qiao Qiao

Date: 28 September 2023



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230559

Ratings & Principle Characteristics:

Specifications table				
Model	ELM3PON003K	ELM3PON004K	ELM3PON005K	ELM3PON006K
PV input				
P _{pv} Max(W)	5100	6000	7500	9000
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	25 x 2	25 x 2	25 x 2	25 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	15 x 2	15 x 2	15 x 2	15 x 2
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	200-850	200-850	200-850	250-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	5.8	7.3	8.7
Max. cont. output current (A)	5.3	7	8.5	10.5
Normal Power (W)	3000	4000	5000	6000
Rated Apparent Power (VA)	3000	4000	5000	6000
Max. cont. Power (W)	3000	4000	5000	6000
Max. cont. Apparent Power (VA)	3000	4000	5000	6000
Power factor(adjustable)	1.0 (-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Oversoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230559

Ratings & Principle Characteristics:

Specifications table				
Model	ELM3PON008K	ELM3PON010K	ELM3PON012K	ELM3PON013K
PV input				
P _{pv} Max(W)	12000	15000	18000	19500
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	25 x 2	25 x 2	25 x 2	25 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	15 x 2	15 x 2	15 x 2	15 x 2
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	300-850	500-850	500-850	500-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	11.6	14.5	17.4	18.9
Max. cont. output current (A)	13.5	17	21.5	22
Normal Power (W)	8000	10000	12000	13000
Rated Apparent Power (VA)	8000	10000	12000	13000
Max. cont. Power (W)	8000	10000	12000	13000
Max. cont. Apparent Power (VA)	8000	10000	12000	13000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230559

Ratings & Principle Characteristics:

Specifications table				
Model	ELM3PON015K	ELM3PON017K	ELM3PON020K	ELM3PON025K
PV input				
P _{pv} Max(W)	22500	25500	30000	37500
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	30 + 48	48 x 2	48 x 2	48 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/2	2/2	2/2	2/2
Max. PV input current (A)	20 + 32	32 x 2	32 x 2	32 x 2
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	500-850	500-850	500-850	500-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	21.8	24.7	29	36.3
Max. cont. output current (A)	27	30	32	40
Normal Power (W)	15000	17000	20000	25000
Rated Apparent Power (VA)	15000	17000	20000	25000
Max. cont. Power (W)	15000	17000	20000	25000
Max. cont. Apparent Power (VA)	15000	17000	20000	25000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.