



Ref. Certif. No.

HU-004626-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

MCB

Name and address of the applicant

Elmark Industries SC
2 Dobrudzha blvd.,
9300 Dobrich
Bulgaria

Name and address of the manufacturer

Elmark Industries SC
2 Dobrudzha blvd.,
9300 Dobrich
Bulgaria

Name and address of the factory

Note: When more than one factory, please report on page 2

Elmark Industries SC
2 Dobrudzha blvd.,
9300 Dobrich
Bulgaria

Ratings and principal characteristics

Ue: 230/400VAC(1P); 230VAC(1P+N); 400VAC(2P/3P/3P+N/4P);
In: 1/2/4/6/10/16/20/25/32/40/50/63A; C-type;
Uimp: 4,0kV; Icn=Ics=6,0kA; Icn1=Icn

Trademark / Brand (if any)

ELMARK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

C61N C62N C63N C64N

Additional information (if necessary may also be reported on page 2)

This Certificate is Amendment No.1 to CBTC ref. No.HU-004626,dated 2023-11-09,it's created for updating of manufacturer and factory's name and address.

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1
See Test Report for National Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

CN23Y8T0 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2024-02-29

Signature:

Wencai Zhang

10/061SMD 2022-07 rke-fix