

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded case circuit breaker

Name and address of the applicant

Elmark Industries SC
2 Dobrudzha blvd.,
9300 Dobrich
Bulgaria

Name and address of the manufacturer

Elmark Industries SC
2 Dobrudzha blvd.,
9300 Dobrich
Bulgaria

Name and address of the factory

Note: When more than one factory, please report on page 2

Elmark Industries SC
2 Dobrudzha blvd.,
9300 Dobrich
Bulgaria

Ratings and principal characteristics

Selectivity category:B; Type of release:Electronic;
3P; Ue=AC415V; In=400A; Icu=85kA; Ics=50kA; Icw=5kA/1s;
Ui=690V; Uimp=6kV

Trademark / Brand (if any)

ELMARK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DS 1

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate


CN23IMEV 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2024-01-12

Signature:



Wencai Zhang